

For More Information

For more information, contact your local water provider at:

Summerville Commissioners of Public Works

Attn: Pat Walton

P.O. Box 817

Summerville, SC 29484-0817

www.summervillecpw.com

Phone: (843) 875-8754

Public meetings normally scheduled:

215 N. Cedar Street

Summerville, SC 29483

4th Tuesday of each month 6:00 pm

We are proud that your drinking water meets or exceeds all federal and state requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels.

EPA requires that all annual water quality reports contain the following statements:

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Summerville Commissioners of Public Works is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganics or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPAs) Safe Drinking Water Hotline at 1-800-426-4791.

The Santee Cooper Regional Water System, EPA, and American Water Works Association have joined forces as part of the Partnership for Safe Water Program. This voluntary program is designed to go beyond the required regulations to provide the highest quality water possible. We are pleased to announce the Santee Cooper Regional Water System recently received the 20 year Partnership for Safe Water Directors Award as part of this program.



ANNUAL DRINKING WATER QUALITY REPORT



We're pleased to report that your water is safe and meets all federal and state requirements.



The Safe Drinking Water Act requires all public water systems to issue an annual report to their customers.

This report is to inform you about the quality water and services we deliver every day. As a service to you, we are pleased to provide you with this annual drinking water quality report. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. Our water source is Lake Moultrie, a 60,000 acre fresh-water lake that is part of the Catawba-Santee water basin. The Source Water Assessment has been completed for the Santee Cooper Regional Water System. A copy of this report can be found on the internet at: http://www.scdhec.gov/sites/default/files/docs/HomeAndEnvironment/Docs/Watershed/wwqa/Santee_WWQA_2013.pdf

In order to provide you with the highest quality water at the most economical price, Berkeley County Water & Sanitation Authority, the City of Goose Creek, Moncks Corner Public Works Commission,

and the Summerville Commissioners of Public Works have joined forces with Santee Cooper in the development of the Santee Cooper Regional Water System. The Santee Cooper Regional Water System is comprised of a 40 million gallon per day surface water treatment plant and 26 miles of water transmission pipeline. This facility began commercial operation in 1994.



The regional system treats and transmits the water to your local water utility for distribution to your home. Your local water utilities maintain approximately 600 miles of distribution pipelines.

We want our valued customers to be informed about their water utility. If you have any questions about your water provider or this report, please contact your local utility listed on the inside of this report. If you want to learn more, please plan to attend one of your local water utilities' regularly scheduled meetings also listed on the inside of this report.

Santee Cooper Regional Water System and your local water utility routinely monitor for constituents in your drinking water according to federal and state laws. The enclosed table shows the results of our monitoring for the period of January 1 to December 31. Some constituents do not require annual testing; therefore, the most recent results have been reported. No reported results are more than 5 years old. All drinking water, including bottled water, may reasonably be



expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these constituents does not necessarily pose a health risk. More information about contaminants and potential health effects can be

obtained by calling EPA's Safe Drinking Water Hotline at 1-800-426-4791

WHAT'S IN THE WATER?

Monitoring Period of Jan. 1 - Dec. 31, 2019

Constituent (units)	MCLG	MCL	Level Detected	Range of Detections	Violation Yes/No	Source of Constituent
Total Coliform Bacteria (P/A)	0	5%	0	0	No	Naturally present in the environment
E. Coli (P/A)	0	0	0	0	No	Human and animal fecal waste
*Turbidity (NTU) – Highest Single Measurement	N/A	TT ≤ 1 NTU	0.27	0.07 – 0.27	No	Soil runoff
*Turbidity (NTU) – Lowest Monthly Percentage of Samples Meeting Limits	0.3 NTU	TT requires 95% of monthly samples ≤ 0.3 NTU	100%	N/A	No	Soil runoff
*Nitrate (measured as nitrogen) (ppm)	10	10	0.40	0.40	No	Runoff from fertilizer use; leaching from septic tanks & sewage; erosion on natural deposits.
TTHM (Total Trihalomethanes) (ppb)	None	80	RAA = 23	13 - 28*	No	By-product of drinking water disinfection
HAA5 (Haloacetic Acid 5) (ppb)	None	60	RAA = 17	12 - 22*	No	By-product of drinking water disinfection
*Fluoride (ppm)	4	4	0.44	0.44	No	Erosion of natural deposits; water additive for strong teeth; discharge from fertilizer & aluminum factories.
*TOC (Total Organic Carbon) (ppm)	N/A	TT	N/A ^b	1.4 - 2.1	No	Naturally present in the environment
Lead (ppb)	0	AL = 15	90th% = 0.79 0 > AL	ND - 3.6	No	Corrosion of household plumbing. Erosion of natural deposits.
Copper, Free (ppm)	1.3	AL = 1.3	90th% = 0.126 0 > AL	ND - 0.224	No	Corrosion of household plumbing. Erosion of natural deposits.
Constituent (units)	MRDL	Level Detected	Range of Detections	Violation Yes/No	Source of Constituent	
*Chloramines (ppm)	4	4	3.00 ^c	2.77 - 3.00	No	Water additive used to control microbes
Chlorine (ppm)	4	4	2.8	1.0 – 3.7	No	Water additive used to control microbes

* Sampling location is Santee Cooper Regional Water System's Treatment Facility

^a Compliance determined by RAA, not individual samples

^b Running Annual Average Removal Ratio for TOC is 1.35. Treatment Technique requires RAA Removal Ratio to be > 1.0

^c Highest Quarterly Average

Note: Lead and Copper Results are from the 2017 sampling period.

Summerville CPW has been designated as a reduced monitoring system for lead and copper by demonstrating low levels of lead and copper over an extended time period. Monitoring is required once every three (3) years.

Fluoride is a naturally occurring element that is added to toothpaste, mouthwash, and public water supplies to help prevent tooth decay. The Santee Cooper Regional Water System maintains fluoride concentrations in accordance with EPA and DHEC recommendations.

Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAA5s) are formed as a by-product of the disinfection process to kill harmful bacteria. In order to minimize the level of TTHMs and HAA5s, a secondary disinfectant (chloramines) which minimizes the formation of TTHMs and HAA5s is added to the distribution system. The above results are based on quarterly sampling in 2019.

MCLs are set at very stringent levels. To understand the possible health effects associated with many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the associated health effect.

General Interest

Sampling Location is Santee Cooper Regional Water System
Monitoring Period of Jan. 1 - Dec. 31, 2019

Constituent (units)	MCL	Average Level Detected
Alkalinity (ppm)	No Standard	14
Total Hardness (ppm)	No Standard	20
Conductivity (umhos/cm)	No Standard	115
Temperature (°C)	No Standard	20.6
pH (SU)	6.5 to 8.5	7.81
Total Dissolved Solids (ppm)	500	70

MORE INFORMATION ABOUT THE WATER

UCMR4 (Unregulated Contaminant Monitoring Rule)

Summerville CPW is currently participating in the UCMR4 program. Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether regulation is warranted. The results for 2019 are listed below.

Constituent	Level Detected (ppb)	Range of Detection (ppb)	Source of Constituent
HAA5 (Haloacetic Acid)	15.5	11.7 - 34.0	By-product of drinking water disinfection
HAA6BR (Haloacetic Acid)	3.2	2.4 - 4.0	By-product of drinking water disinfection
HAA9 (Haloacetic Acid)	18.7	14.1 – 37.2	By-product of drinking water disinfection
Manganese	1.7	1.3 – 2.0	Naturally-occurring element; commercially available in combination with other elements and minerals

WHAT'S NOT IN THE WATER:

Constituent	Level Detected (ppb)	Range of Detection (ppb)	Source of Constituent
Germanium	ND	ND	Naturally-occurring element
Chlorpyrifos	ND	ND	Used as an insecticide
Total Permethrin	ND	ND	Used as an insecticide
alpha-hexachlorocyclohexane	ND	ND	Used as an insecticide
Dimethipin	ND	ND	Used as an herbicide and defoliant
Oxyfluorfen	ND	ND	Used as an herbicide
Profenofos	ND	ND	Used as an insecticide
Tebuconazole	ND	ND	Used as a fungicide
Tribufos	ND	ND	Used as an insecticide
Ethoprop	ND	ND	Used as an insecticide
Butylated hydroxyanisole	ND	ND	Used as an antioxidant and food preservative
o-Toluidine	ND	ND	Used in the production of dyes, rubber, pharmaceuticals and pesticides
Quinoline	ND	ND	Used as a pharmaceutical and flavoring agent
1-Butanol	ND	ND	Used as a solvent, food additive and in production of other chemicals
2-Methoxyethanol	ND	ND	Used as an industrial solvent
2-Propen-1-ol	ND	ND	Used in the production flavorings, perfumes, and other chemicals
Cylindrospermopsin	ND	ND	Produced by cyanobacteria in lakes, rivers, and other water sources
Anatoxin-a	ND	ND	Produced by cyanobacteria in lakes, rivers, and other water sources
Total microcystin	ND	ND	Produced by cyanobacteria in lakes, rivers, and other water sources

Abbreviations & Definitions

- AL - Action Level - concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow
- MCL - Maximum Contaminant Level - is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- MCLG - Maximum Contaminant Level Goal - is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- MRDL - Maximum Residual Disinfectant Level - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- MRDLG - Maximum Residual Disinfectant Level Goal - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- N/A - Not Applicable
- ND - Non-Detectable - laboratory analysis indicates that the constituent is not present at the detection limit.
- NTU - Nephelometric Turbidity Unit - measure of the clarity of water
- P/A - Present/Absent
- ppb - parts per billion or ug/l - micrograms per liter - one part per billion corresponds to one minute in 2,000 years
- ppm - parts per million or mg/l - milligrams per liter - one part per million corresponds to one minute in two years
- RAA - Running Annual Average
- SU - Standard Unit
- TT - Treatment Technique - required process intended to reduce the level of a contaminant in drinking water
- umhos/cm - Micromhos per centimeter - measure of the ability for water to conduct electricity